



$T = 16$ square meters per day (1,300 gallons per day per foot) - Drawdown data

$T = 66$ square meters per day (5,300 gallons per day per foot) - Recovery data

Figure D-5

Published Pumping Test Results for Well TW-2 (Winograd and Thordarson, 1975)