



$T = 137 \text{ square meters per day (11,000 gallons per day per foot) - Drawdown data}$

$T = 335 \text{ square meters per day (27,000 gallons per day per foot) - Recovery data}$

Figure D-10

Published Pumping Test Results for Well TW-4 (Winograd and Thordarson, 1975)