



$T = 248$ square meters per day (20,000 gallons per day per foot) - Drawdown data
 $T = 658$ square meters per day (53,000 gallons per day per foot) - Recovery data

Figure D-13
 Published Pumping Test Results for Well TW-10 (Winograd and Thordarson, 1975)