

Table 7-2
Transmissivity Obtained from
Multislope Drawdown Responses

Well Name	Transition Slope Value		Steep Slope Value		Percent Difference
	(m ² /d) ^a	(gpd/ft) ^b	(m ² /d)	(gpd/ft ²)	
Army #1 Water Well	481	38,690	214	17,200	55
Water Well 2	16	1,267	5	387	69
Water Well 8	3,243	261,000	1,150	92,600	65
UE-16d	477	38,367	181	14,541	62
UE-2ce	19	1,530	11	904	41

^a Meters squared per day
^b Gallons per day per foot