

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 12208

1. OWNER Russ Avery ADDRESS AT WELL LOCATION: 1/4 mile south of
 MAILING ADDRESS: 381 Lime Circle Mile Marker 14 SR322 URSINE NV
HENDERSON NV 89015

2. LOCATION 1/4 S 1/4 E 1/4 Sec. 10 T. 1 N. R. 69 E Lincoln County
 PERMIT NO. WATER R-1009 Parcel No. 3 Subdivision Name _____
Issued by Water Resources

3. WORK PERFORMED New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
TOP Soil		0	6	6
Sand - Gravel - Boulders	X	6	76	70
Hard Rock		76	80	4
TD 80'				
WATER # R-1009				

8. WELL CONSTRUCTION
 Depth Drilled 80 Feet Depth Cased 80 Feet

HOLE DIAMETER (BIT SIZE)
 From 12 1/4 Inches To 0 Feet 80 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/4</u>	<u>0</u>	<u>.158</u>	<u>0</u>	<u>80</u>

Perforations:
 Type perforation torch cut
 Size perforation 1/8" x 6"
 From 55 feet to 80 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 50

Placement Method: Pumped Poured

Gravel Packed: Yes No
 From 50 feet to 80 feet

9. WATER LEVEL
 Static water level: 21 feet below land surface
 Artesian flow 0 G.P.M. P.S.I.
 Water temperature 58.1 °F Quality good

Date started 12-5-96, 19_____
 Date completed 12-10-96, 19_____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>17</u>	<u>18</u>	<u>2</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Davis Drilling and Pumps Contractor
 Address P.O. Box 54 Contractor
Hiko NV 89017

Nevada contractor's license number issued by the State Contractor's Board 0028266
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 1191

Signed Mike Davis
 By driller performing actual drilling on site or contractor

Date 12-10-96

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 12208

1. OWNER Russ Avery ADDRESS AT WELL LOCATION: 1/4 mile south of
 MAILING ADDRESS: 381 Lime Circle Mile Marker 14 SR322 URSINE NV
HENDERSON NV 89015

2. LOCATION 1/4 S 1/4 E 1/4 Sec. 10 T. 1 N. S. R. 69 E Lincoln County
 PERMIT NO. WATER R-1009 Parcel No. 3 Subdivision Name _____
Issued by Water Resources

3. WORK PERFORMED New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
TOP Soil		0	6	6
Sand - Gravel - Boulders	X	6	76	70
Hard Rock		76	80	4
TD 80'				
WATER # R-1009				

8. WELL CONSTRUCTION
 Depth Drilled 80 Feet Depth Cased 80 Feet

HOLE DIAMETER (BIT SIZE)
 From 12 1/4 Inches To 0 Feet 80 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>	<u>0</u>	<u>.158</u>	<u>0</u>	<u>80</u>

Perforations:
 Type perforation torch cut
 Size perforation 1/8" x 6"
 From 55 feet to 80 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement
 Depth of Seal 50 Cement Grout
 Placement Method: Pumped Concrete Grout
 Poured

Gravel Packed: Yes No
 From 50 feet to 80 feet

9. WATER LEVEL
 Static water level: 21 feet below land surface
 Artesian flow 0 G.P.M. P.S.I.
 Water temperature 58.1 °F Quality good

Date started 12-5-96, 19_____
 Date completed 12-10-96, 19_____
 7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>17</u>	<u>18</u>	<u>2</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Davis Drilling and Pumps Contractor
 Address P.O. Box 54 Contractor
Hiko NV 89017
 Nevada contractor's license number issued by the State Contractor's Board 0028266
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 1191
 Signed Mike Davis
 By driller performing actual drilling on site or contractor
 Date 12-10-96