

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 47659
 Permit No. _____
 Base _____
 NOTICE OF INTENT NO. 14135

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Frank Lloyd ADDRESS AT WELL LOCATION 2 miles North of Eagle Valley Reservoir
 MAILING ADDRESS P.O. Box 81 Pioche Nev. 89043 NEV. 89043
 2. LOCATION N/w 1/4 N/w 1/4 Sec. 18 T 2 N 70 E Lincoln County
 PERMIT NO. _____ Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|---------------------|--------------|------|----|------------|
| TOP Soil | | 0 | 6 | 6 |
| Hard Rock - Granite | | 6 | 62 | 56 |
| Coarse Gravel | X | 62 | 80 | 18 |
| White Clay | | 80 | 85 | 5 |

7. WELL TEST DATA

| TEST METHOD: | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|--|--------|-------------------------------|--------------|
| <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift | 35 | 0 | 1 |

8. WELL CONSTRUCTION
 Depth Drilled 85 Feet Depth Cased 85 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 0 Feet 85 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| <u>6 5/8</u> | <u>2</u> | <u>1.88</u> | <u>0</u> | <u>85</u> |

 Perforations:
 Type perforation factory
 Size perforation 1/8" x 3"
 From 65 feet to 85 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 85 feet
 9. WATER LEVEL
 Static water level 16' feet below land surface
 Artesian flow 0 G.P.M. 0 P.S.I.
 Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Davis Drilling Contractor
 Address P.O. Box 54 Contractor
Hiko, Nev. 89017
 Nevada contractor's license number issued by the State Contractor's Board 0028966
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 1191
 Signed Mike Davis
 By driller performing actual drilling on site or contractor
 Date 6-20-95

