

OFFICE USE ONLY
 Log No. 74556
 Permit No. 207
 Basin 30865

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 30865

1. OWNER LEROY CAMPBELL ADDRESS AT WELL LOCATION 14 N Preston Av.
 MAILING ADDRESS HL 34 Box 34065 Ely NV 89301

2. LOCATION SE 1/4 SE 1/4 Sec 12 T 12 N/S R. 61 E White Pine County White Pine
 PERMIT NO. N/A 013-023-03 Preston town site
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clay top Soil		0	7	
gravel conglomerate		7	30	
Clay con.		30	53	
gravel		53	54	
Clay gravel con.		54	60	
gravel con.		60	63	
Clay con.		63	75	
gravel con.	water	75	78	
Clay conglomerate		78	84	
gravel	water	84	86	
Clay con.		86	93	
gravel	water	93	96	
Clay con.		96	105	
gravel	water	105	106	
Clay con.		106	113	
gravel con.	water	113	116	
Clay con.		116	120	

8. WELL CONSTRUCTION
 Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)

From	To
<u>10</u> Inches	<u>0</u> Feet <u>50</u> Feet
<u>8</u> Inches	<u>50</u> Feet <u>120</u> Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/4</u>	<u>12.9</u>	<u>.188</u>	<u>1</u>	<u>120</u>

Perforations:
 Type perforation mill
 Size perforation 4 x 2.5 x 6 Row

From 78 feet to 120 feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 50

Placement Method: Pumped Poured

Gravel Packed: Yes No
 From 50 feet to 120 feet

RECEIVED
 99 JAN 26 AM 10 48
 STATE ENGINEERS OFFICE

Date started Dec 4 1998
 Date completed Dec 28 1998

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>40</u>	<u>2'</u>	<u>1 hr</u>

9. WATER LEVEL
 Static water level 7.2 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Nathan R. Maynard Contractor
 Address P.O. Box 174 Lucid NV 89317 Contractor

Nevada contractor's license number issued by the State Contractor's Board 0022869
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1556

Signed Owner
 By driller performing actual drilling on site or contractor
 Date Jan 19 - 99