X

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. I
Permit No.
Basin 207

NOTICE OF INTENT NO. 22963

1. OWNER David & Tawnya Hendrix
MAILING ADDRESS Po Box 12 Lund NV 89317
ADDRESS AT WELL LOCATION 18 N 100 E

2. LOCATION SE ¼ NE ¼ Sec. 33 T. 12 N/S R. 62 E White Pine County
PERMIT NO. N/A (Issued by Water Resources) 6-023-01 (Parcel No.) Lund town Site Survey (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[X] Cable [ ] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy top Soil		0	4	
Sandy clay		4	10	
Lime gravel con.		10	13	
clay		13	15	
gravel		15	20	
clay conglomerate		20	25	
gravel con.		25	30	
gravel clay con.		30	36	
clay		36	37	
gravel con.		37	38	
clay con.		38	42	
gravel con		42	51	
clay		51	54	
gravel	water	54	55	
clay		55	65	
clay		65	70	
gravel	water	70	73	
clay gravel con		73	75	
gravel	water	75	76	
clay con		76	78	
gravel	water	78	80	
clay con.		80	90	
gravel	water	90	92	
Sandy clay		92	100	
gravel	water	100	101	
clay con		101	108	
gravel	water	108	109	
Sandy clay		109	118	
gravel	water	118	120	

STATE ENGINEER'S OFFICE DEC 04

Date started Nov 14, 1994
Date completed Dec 8, 1994

7. WELL TEST DATA
TEST METHOD: [X] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
35	5'	1 hr.

8. WELL CONSTRUCTION
Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	50 Feet
8 Inches		50 Feet	120 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	-1	120

Perforations:
Type perforation mill
Size perforation 5/8 x 2.5 x 6 row
From feet to feet
From 57 feet to 78 feet
From 99 feet to 120 feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 120 feet

9. WATER LEVEL
Static water level 45 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Nathan R Maynard (Contractor)
Address Po Box 176 Lund NV 89317 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 0022869
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1556
Signed Owen Maynard (By driller performing actual drilling on site or contractor)
Date Dec 20 -94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627