WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 67403
Permit No.
Basin 207

NOTICE OF INTENT NO. 30854

1. OWNER Howard Bugher
MAILING ADDRESS Po Box 51 Lund NV 89317
ADDRESS AT WELL LOCATION Hwy 318

2. LOCATION SE ¼ NW ¼ Sec. 28 T. 12 N/S R. 62 E White Pine County
PERMIT NO. N/A (Issued by Water Resources) 13-086-08 (Parcel No.) Lund ten acre plat (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC ☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	1	
cobble gravel sand		1	5	
cobble gravel con.		5	21	
gravel Clay con.		21	40	
gravel con		40	41	
Clay con		41	48	
gravel con		48	50	
Clay con		50	60	
gravel con		60	61	
Clay con		61	69	
grabel con.		69	70	
clay con		70	82	
gravel	water	82	84	
Clay conglomerate		84	90	
gravel	water	90	91	
clay con		91	104	
gravel	water	104	105	
gravel	water	105	110	
Clay		110	119	
gravel	water	119	120	
clay		120	129	
gravel	water	129	132	
clay		132	135	

Date started May 23, 1997
Date completed June 13, 1997

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30	4	1 hr.

8. WELL CONSTRUCTION
Depth Drilled 135 Feet Depth Cased 135 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	55 Feet
8 Inches		55 Feet	135 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	-1	135

Perforations:
Type perforation mill
Size perforation 1/4 x 2.5 x 6 row
From 1 feet to feet
From 23 feet to 94 feet
From 114 feet to 135 feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 55'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 55 feet to 135 feet

9. WATER LEVEL
Static water level 80 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Nathan R Maynard (Contractor)
Address Po Box 176 Lund NV 89317 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 0022869
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1556
Signed Darren Maynard (By driller performing actual drilling on site or contractor)
Date July 5 - 97

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627