

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 3033
6 miles south of Ely

1. OWNER Mike McIntosh ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 973 Avenue C _____
Ely, NV 89301 _____

2. LOCATION NE 1/4 SW 1/4 Sec. 12 T. 15 N. 8 R. 63 E White Pine County _____
 PERMIT NO. 1277006 lot 9 Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	1	1
Clay & Gravel		1	10	9
Gravel		10	30	20
Clay & Gravel		30	35	5
Gravel		35	40	5
Clay & Gravel		40	50	10
Gravel		50	120	70
Clay & Gravel		120	145	25
Sand & Gravel		145	200	55
Clay & Gravel		200	210	10
Water Sand & Gravel	x	210	220	10
Clay & Gravel		220	235	15
Water Sand & Gravel	x	235	270	35
Clay & Gravel		270	275	5
Water Sand & Gravel	x	275	285	10
Clay & Gravel		285	290	5
Clay/Water Sand & Gravel	x	290	309	19

8. WELL CONSTRUCTION
 Depth Drilled 309 Feet Depth Cased 309 Feet

HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 0 Feet
0 Inches Feet 309 Feet
 _____ Inches Feet _____ Feet
 _____ Inches Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	309

Perforations:
 Type perforation Factory
 Size perforation 1/8" x 2 1/2" 6 rows
 From 209 feet to 309 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 ft. Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 309 feet

9. WATER LEVEL
 Static water level: 210 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality GOOD

Date started May 8, 19 96
 Date completed May 11, 19 96

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>25</u>	<u>90</u>	<u>1 1/2</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Christiansen Drilling Inc Contractor
 Address 557 Ely Avenue Contractor
Ely, NV 89301

Nevada contractor's license number issued by the State Contractor's Board: 14790
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 641

Signed June 5, 1996
 By driller performing actual drilling on site or contractor
 Date June 5, 1996