

OFFICE USE ONLY  
 Log No. 7240  
 Permit No. 125  
 Basin. \_\_\_\_\_

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in  
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. \_\_\_\_\_

1. OWNER Gail Parker ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS Ida Pah Ut. 84034 \_\_\_\_\_  
 2. LOCATION SE 1/4 SW 1/4 Sec 34 T. 15 N. R. 70 E. White Pipe County \_\_\_\_\_  
 PERMIT NO. \_\_\_\_\_ Issued by Water Resources \_\_\_\_\_ Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Gravel + firm clay	no	0	3	3
Brown clay	no	3	5	2
Coarse gravel	seep	5	14	9
light clay, sand & gravel	↑	14	65	51
Not much show of water until 49 to 65'				

8. WELL CONSTRUCTION  
 Depth Drilled 65 Feet Depth Cased 65 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
10 Inches 0 Feet 65 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>25.03</u>	<u>.375</u>	<u>+ 1/2</u>	<u>65</u>

Temporary 10" conductor casing used & pulled  
 Perforations:  
 Type perforation Trench  
 Size perforation 3/16" x 5"  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From 50 feet to 65 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal 50  
 Placement Method:  Pumped  Poured via Trimie Pipe  
 Gravel Packed:  Yes  No  
 From 50 feet to 65 feet

9. WATER LEVEL  
 Static water level 8 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started 15 July, 1998  
 Date completed 4 Aug, 1998

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input checked="" type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>20</u>	<u>2'</u>	<u>3 hrs.</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Boley + Henry Contractor  
 Address 23551 Hwy 30 W Contractor  
Muntzugh, Id 83344  
 Nevada contractor's license number issued by the State Contractor's Board 4641 A.  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 517  
 Signed Blaine Boley is partner  
 By driller performing actual drilling on site or contractor  
 Date 4 Aug 1998

RECEIVED  
 98 AUG - 7 AM 9:37  
 STATE ENGINEERING OFFICE