DIVISION OF WATER RESOURCES

DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 13274
Permit No. 25919
Basin

RICHARD C. & KIM LEWIS

1. OWNER ~~PAUL HENRIE #2~~ ADDRESS MAPA NEV.

2. LOCATION NW ¼ NW ¼ Sec. 22 T. 14 N/S R. 66 E. CLARK County
PERMIT NO. 25919 REPLACEMENT 32061 - 51283

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☒ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND GRAVEL + CLAY	X	0	110	110
CEMENTED GRAVEL		110	113	3
COARSE SAND + CLAY	X	113	137	20

8. WELL CONSTRUCTION
Diameter hole 17½ inches Total depth 137 feet
Casing record
Weight per foot Thickness 1/8"

Diameter	From	To
10 inches	41 feet	137 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☐ No ☒ Type
Depth of seal feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 0 feet to 137 feet

Perforations:
Type perforation TORCH
Size perforation 1½ X 10 ROWS
From 41 feet to 137 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 21 Feet below land surface
Flow G.P.M.
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name CHAPARRAL DRLG + PUMPS
Address 4161 CANAL LAS VEGAS
Nevada contractor's license number 10791
Nevada driller's license number 635
Signed
Date 1-15-73

Date started 12-28, 19 72
Date completed 1-6, 19 73

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 250 Draw down 30 feet 8 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

USE ADDITIONAL SHEETS IF NECESSARY

5471