

OFFICE USE ONLY
 Log No. 28575
 Permit No. _____
 Basin 216



WELL DRILLERS REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 4291

1. OWNER Fru-Con Construction Corp. ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 1299 Clayton Rd. West
Ballwin, Mo. 63011

2. LOCATION SE 1/4 SE 1/4 Sec 5 T 18 64 E Clark County
 PERMIT NO. _____

Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Fill		0	4	4
Gray rock		4	22	18
Gray clay, sand & gravel		22	40	18
White clay		40	140	100
Clay, some gravel		140	320	180
Sandy clay		320	376	56
Gravel		376	382	6
Clay, sand & gravel		398	420	22
Gray rock		420	440	20
Fractured rock		440	500	60
Fractured rock, some clay		500	560	60
Clay, some gravel		560	580	20
Clay, sand & gravel		580	600	20
Gravel		600	640	40
Silty clay		640	660	20
Clay		660	700	40
Dry hole - filled with cement				

RECEIVED
 JUN 04 1987
 Div. of Water Resources
 Branch Office - Las Vegas, NV

Date started January 12, 1987
 Date completed January 24, 1987

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M.	Draw down	feet	hours

8. WELL CONSTRUCTION
 Diameter hole 12 1/2 inches Total depth 700 feet
 Casing record Well abandoned - no t cased
 Weight per foot _____ Thickness _____

Diameter	From	To
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type _____
 Depth of seal _____ feet
 Gravel packed: Yes No
 Gravel packed from _____ feet to _____ feet

Perforations:
 Type perforation _____
 Size perforation _____
 From _____ feet to _____ feet
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level _____ feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ ° F. Quality _____

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name THOMPSON DRILLING CO., INC.
4185 West Harmon
 Address Las Vegas, Nevada 89103
 Contractor
 Nevada contractor's license number 4286A
 Nevada contractor's drillers number 290
 Nevada driller's license number 856 (Griffiths)
 Actual Driller
 Signed Richard K. Thompson
 Contractor
 Date June 3, 1987