

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 11672

1. OWNER CLARK SANITATION INC. ADDRESS AT WELL LOCATION APEX SITE  
 MAILING ADDRESS \_\_\_\_\_  
 2. LOCATION NE 1/4 NW 1/4 Sec. 18 T. 18 N/S R. 64 E CLARK County \_\_\_\_\_  
 PERMIT NO. 3/W-3048 by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SAND & ROCKS		0	5	5
RED SHALE		5	40	35
HARD RED SHALE		40	270	230
W/ STRKS OF GYPSUM				
GYPSUM		270	300	30
RED SANDSTONE W/ STRKS OF GYPSUM		300	530	230
GYPSUM		530	625	95
HARD RED SHALE W/ STRKS. OF GYPSUM		625	700	75
LIMESTONE		700	983	283

8. WELL CONSTRUCTION  
 Depth Drilled 983 Feet Depth Cased 983 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 12 Inches 0 Feet 850 Feet  
 To 7 7/8 Inches 850 Feet 983 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>	<u>16.94</u>	<u>1.188</u>	<u>1</u>	<u>836</u>
<u>6 5/8</u>	<u>12.92</u>	<u>1.188</u>	<u>820</u>	<u>983</u>

Perforations:  
 Type perforation FACTORY SAW  
 Size perforation 18 x 2 1/2  
 From 883 feet to 963 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 830  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

RECEIVED  
 SEP 14 1993  
 Div. of Water Resources  
 Branch Office - Las Vegas, NV

Date started 8-26, 1993  
 Date completed 9-3, 1993

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

9. WATER LEVEL  
 Static water level 596 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name WATER WELL SERVICES Contractor  
 Address 6475 GARY AVE Contractor  
LAS VEGAS, NV 89139  
 Nevada contractor's license number issued by the State Contractor's Board 022311  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 694  
 Signed Pyndale Couch  
 By driller performing actual drilling on site or contractor  
 Date 9-10-93