WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 76859
Permit No.
Basin

NOTICE OF INTENT NO. 19454

1. OWNER Lee Zabriskie
MAILING ADDRESS PO Box 368 Sandy Valley NV 89019
ADDRESS AT WELL LOCATION 5 miles North of Caliente on US 93 west side

2. LOCATION N/W ¼ N/W ¼ Sec 28 T 3 N/S R 67 E/W Lincoln County
PERMIT NO. — Issued by Water Resources
Parcel No. 13-020-21
Subdivision Name —

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	8	8
Sand-Boulders		8	50	42
Hard Rock		50	55	5
Sand-Gravel	X	55	100	45
Fractured Rock		100	120	20
Sand-Boulders	X	120	150	30
Hard Rock		150	153	3

DCNR/DWR Received OCT 4 1996 LAS VEGAS OFFICE

Date started 8-4-95, 19
Date completed 8-6-95, 19

7. WELL TEST DATA
TEST METHOD: [X] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
14	4	4

8. WELL CONSTRUCTION
Depth Drilled 153 Feet Depth Cased 153 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8 Inches		0 Feet	153 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	-	Sch 40	0	153

Perforations:
Type perforation Jaw cut
Size perforation 1/8" x 6"
From 93 feet to 113 feet
From 133 feet to 153 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 153 feet

9. WATER LEVEL
Static water level 22 feet below land surface
Artesian flow — G.P.M. P.S.I.
Water temperature cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Davis Drilling and Pumps Contractor
Address PO. Box 54 Hiko NV 89017 Contractor

Nevada contractor's license number issued by the State Contractor's Board 0028866
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1191
Signed Mike Davis By driller performing actual drilling on site or contractor
Date 9-12-95