

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24048

1. OWNER John Thompson ADDRESS AT WELL LOCATION #2 Carrigan  
 MAILING ADDRESS P.O. Box 1013 Caliente NV Ave 7 miles north of Caliente  
89008  
 2. LOCATION S1E 1/4 SW 1/4 Sec 11 T 3 N R. 67 E Lincoln County  
 PERMIT NO. \_\_\_\_\_ Parcel No. 013-160-39 Subdivision Name Carrigan  
 Issued by Water Resources

3. WORK PERFORMED  New Well  Replace  Recondition  Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  Domestic  Municipal/Industrial  Irrigation  Monitor  Test  Stock

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>TOP Soil - Gravel</u>		<u>0</u>	<u>20</u>	<u>20</u>
<u>Sand - Gravel - Boulders</u>		<u>20</u>	<u>125</u>	<u>105</u>
<u>Gravel - Boulders</u>	<u>X</u>	<u>125</u>	<u>145</u>	<u>20</u>
<u>Clay - Boulders</u>	<u>X</u>	<u>145</u>	<u>165</u>	<u>20</u>
<u>Clay</u>		<u>165</u>	<u>170</u>	<u>5</u>

8. WELL CONSTRUCTION  
 Depth Drilled 170 Feet Depth Cased 170 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 0 To 170  
10 5/8 Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 1/2</u>		<u>sch 40</u>	<u>0</u>	<u>170</u>

Perforations:  
 Type perforation 5 1/2" cut  
 Size perforation 1 1/8" x 6"  
 From 50 feet to 70 feet  
 From 70 feet to 170 feet  
 From 130 feet to 170 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  Neat Cement  Cement Grout  Concrete Grout  
 Depth of Seal 50  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 50 feet to 170 feet

9. WATER LEVEL  
 Static water level 72 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ S.F.  
 Water temperature 56.5 °F Quality good

Date started 9-22-02, 20\_\_\_\_\_  
 Date completed 9-23-02, 20\_\_\_\_\_  
 7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>14</u>	<u>12</u>	<u>3</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Davis Drilling and Pumps Contractor  
 Address HC 61 Box 54 Hills NV 89017 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 0028266  
 Nevada driller's license number issued by the Division of Water Resources the on-site driller 1191  
 Signed Mike Davis  
 By driller performing actual drilling on site or contractor  
 Date 9-23-02