

OFFICE USE ONLY
 Log No. 70576
 Permit No. 63238
 Basin. 209

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 15894

1. OWNER Givers Gain LLC ADDRESS AT WELL LOCATION 400' East of
 MAILING ADDRESS 2755 East Desert Inn Olama West Road 1/2 miles South of
Road Las Vegas NV 89109 Lagan Supply Olama NV 89001
 2. LOCATION S/E 1/4 N/E 1/4 Sec. 31 T. 6 N 61 E Lincoln County
 PERMIT NO. 632-38 11-192-03 Parcel No. Subdivision Name

3. WORK PERFORMED New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
TOP Soil - Boulders		0	19	19
clay		19	73	54
clay - Gravel		73	79	6
Sand - Boulders		79	84	5
clay		84	140	56
Sand - gravel	Y	140	147	7
clay - sand		147	165	18
Sand - Boulders	X	165	223	58
clay		223	231	8

8. WELL CONSTRUCTION
 Depth Drilled..... Feet Depth Cased..... Feet
 HOLE DIAMETER (BIT SIZE)
 From To
13 Inches 0 Feet 228 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 3/4</u>	<u>0</u>	<u>.188</u>	<u>0</u>	<u>228</u>

Perforations:
 Type perforation Factory
 Size perforation 1/2" x 3"
 From 51 feet to 71 feet
 From 91 feet to 111 feet
 From 131 feet to 171 feet
 From 211 feet to 231 feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 231 feet

9. WATER LEVEL
 Static water level 8.6 feet below land surface
 Artesian flow 0 G.P.M. 0 P.S.I.
 Water temperature cool °F Quality fair

Date started 1-16-98, 19____
 Date completed 1-21-98, 19____

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input checked="" type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<u>53</u>	<u>124</u>	<u>10</u>	

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Davis Drilling and Pumps Contractor
 Address P.O. Box 54 Contractor
Hiko NV 89017
 Nevada contractor's license number issued by the State Contractor's Board 0028966
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1191
 Signed Mike Davis
 By driller performing actual drilling on site or contractor
 Date 1-21-98