

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Log No. 88089  
 Permit No. 11499  
 Basin 220  
 NOTICE OF INTENT NO. 25758

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

OWNER Simplot ADDRESS AT WELL LOCATION 665 Simplot Rd  
 MAILING ADDRESS PO Box 308  
Overton, NV 89040  
 2. LOCATION SE 1/4 NW 1/4 Sec 30 T 16 N R 68 E Clark County  
 PERMIT NO. 11499 720-590-001 or 071-30-201-002  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Perforated with mills knife				
From 200' up to 50'				
At 50' we broke knife				
on perforator. Replaced blade				
and tried again.				
Knife did not want to cut				
pvc so we thought we had				
come up to surface seal.				
Pumped 6 cu yds of neat				
cement through 2" trimmic				
line with concrete pump.				

8. WELL CONSTRUCTION  
 Depth Drilled 200' Feet Depth Cased 200' Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
 Inches Feet Feet  
 Inches Feet Feet  
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>1 3/4</u>		<u>.250</u>	<u>0</u>	<u>200</u>

Perforations:  
 Type perforation Mills knife  
 Size perforation 3/4 x 3  
 From 50 feet to 200 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 200' sealed  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 26' feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Webber Drilling Contractor  
 Address 2475 W. 3935 S. Contractor  
West Valley City, Ut. 84119  
 Nevada contractor's license number issued by the State Contractor's Board 0025887  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1557  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date Dec 28, 2002

Date started July 27, 2002 19\_\_\_\_  
 Date completed July 27, 2002 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

